

SASKATCHEWAN RIVER BASIN

FORECAST OF STREAMFLOWS AND RESERVOIR LEVELS

October 23, 2025

Date	SOUTH SASKATCHEWAN RIVER					NORTH SASKATCHEWAN RIVER	
	Lake Diefenbaker				Saskatoon	Alberta Border	Prince Albert
	Daily Mean Inflow (m ³ /s)	Daily Mean Elevation (m)	Qu'Appelle River Dam Mean Outflow (m ³ /s)	Gardiner Dam Daily Mean Outflow (m ³ /s)	Daily Mean Flow (m ³ /s)	Daily Mean Flow (m ³ /s)	Daily Mean Flow (m ³ /s)
Oct 23, 2025	115	555.10	2	90	92	137	138
Oct 24, 2025	113	555.10	2	90	91	143	139
Oct 25, 2025	116	555.10	2	90	90	140	144
Oct 26, 2025	113	555.11	2	90	90	138	145
Oct 27, 2025	112	555.11	2	90	90	139	145
Oct 28, 2025	114	555.11	2	90	90	137	140
Oct 29, 2025	114	555.11	2	90	90	134	141
Oct 30, 2025	113	555.12	2	90	90	132	140
Oct 31, 2025	114	555.12	2	90	90	131	140
Nov 1, 2025	116	555.12	2	90	90	133	139

Date	SASKATCHEWAN RIVER					
	Codette Reservoir			Tobin Lake		Cumberland Lake
	Daily Mean Inflow (m ³ /s)	Daily Mean Elevation (m)	Daily Mean Outflow (m ³ /s)	Daily Mean Elevation (m)	Daily Mean Outflow (m ³ /s)	Daily Mean Elevation (m)
Oct 23, 2025	230	347.61	220	313.50	220	264.71
Oct 24, 2025	229	347.61	220	313.50	220	264.70
Oct 25, 2025	229	347.60	220	313.51	220	264.69
Oct 26, 2025	234	347.63	220	313.51	220	264.67
Oct 27, 2025	235	347.62	240	313.52	220	264.66
Oct 28, 2025	233	347.61	240	313.53	220	264.65
Oct 29, 2025	232	347.58	240	313.54	220	264.64
Oct 30, 2025	230	347.54	240	313.55	220	264.63
Oct 31, 2025	230	347.49	240	313.56	220	264.63
Nov 1, 2025	230	347.63	180	313.56	200	264.62

Notes:

This forecast is a guideline valid at the point of issue and based on operations intended at the time. It also relies upon data which contains inherent uncertainties, and as with all forecasts the uncertainties in the estimates increase the further away from the date of issue. Specific values on specific days may differ due to transient conditions, especially during periods of rapid change.

Flows provided in the table above are mean (average) daily flows. Flows can however be expected to fluctuate during the day, particularly below the reservoirs on the system (Diefenbaker, Codette, and Tobin) where SaskPower adjusts outflows throughout the day to meet the Province's demands for electricity. Immediately below these reservoirs, outflows are generally higher during the daytime period and much lower, or even zero at times, during the overnight period. The timing of these fluctuations will change but the magnitude will decrease with distance downstream of the reservoirs.

The next forecast will be issued on or around October 30, 2025.