

SASKATCHEWAN RIVER BASIN

FORECAST OF

STREAMFLOWS AND RESERVOIR LEVELS

September 24, 2026

Date	SOUTH SASKATCHEWAN RIVER				NORTH SASKATCHEWAN RIVER	
	Lake Diefenbaker			Saskatoon	Alberta Border	Prince Albert
	Daily Mean Inflow (m ³ /s)	Daily Mean Elevation (m)	Gardiner Dam Daily Mean Outflow (m ³ /s)	Daily Mean Flow (m ³ /s)	Daily Mean Flow (m ³ /s)	Daily Mean Flow (m ³ /s)
Sep 25, 2026	188	555.61	130	131	183	199
Sep 26, 2026	183	555.61	130	130	172	207
Sep 27, 2026	183	555.62	130	130	167	214
Sep 28, 2026	180	555.63	130	130	166	212
Sep 29, 2026	175	555.64	130	130	151	205
Sep 30, 2026	169	555.64	130	130	145	199
Oct 1, 2026	163	555.65	130	130	140	189
Oct 2, 2026	154	555.65	130	130	135	184
Oct 3, 2026	147	555.65	130	130	131	178
Oct 4, 2026	142	555.65	130	130	128	171
Date	SASKATCHEWAN RIVER					
	Codette Reservoir			Tobin Lake		Cumberland Lake
	Daily Mean Inflow (m ³ /s)	Daily Mean Elevation (m)	Daily Mean Outflow (m ³ /s)	Daily Mean Elevation (m)	Daily Mean Outflow (m ³ /s)	Daily Mean Elevation (m)
Sep 25, 2026	320	347.51	290	313.52	270	264.99
Sep 26, 2026	328	347.60	280	313.52	280	264.97
Sep 27, 2026	338	347.80	280	313.51	280	264.96
Sep 28, 2026	342	347.72	330	313.51	290	264.95
Sep 29, 2026	340	347.72	330	313.52	290	264.94
Sep 30, 2026	335	347.70	330	313.53	290	264.93
Oct 1, 2026	328	347.70	330	313.53	290	264.92
Oct 2, 2026	321	347.62	330	313.54	290	264.91
Oct 3, 2026	314	347.74	260	313.54	260	264.91
Oct 4, 2026	308	347.84	260	313.53	260	264.90

Notes:

This forecast is a guideline valid at the point of issue and based on operations intended at the time. It also relies upon data which contains inherent uncertainties, and as with all forecasts the uncertainties in the estimates increase the further away from the date of issue. Specific values on specific days may differ due to transient conditions, especially during periods of rapid change.

Flows provided in the table above are mean (average) daily flows. Flows can however be expected to fluctuate during the day, particularly below the reservoirs on the system (Diefenbaker, Codette, and Tobin) where SaskPower adjusts outflows throughout the day to meet the Province's demands for electricity. Immediately below these reservoirs, outflows are generally higher during the daytime period and much lower, or even zero at times, during the overnight period. The timing of these fluctuations will change but the magnitude will decrease with distance downstream of the reservoirs.